



P.O. Box 4376
Tequesta, FL 33469
Phone (561) 222-2993
Fax (561) 222-2994
tjmarais@aol.com

space planning and architecture

License #: AA26000521

ADDENDUM 1

DATE: March 30, 2016

PROJECT NAME: Advanced Vision Care
3893 Military Trail
Suite #4
Jupiter, Florida

GENERAL:

The following additions, deletions, clarifications, or corrections to the drawings are to be considered as much a part of the Bidding Documents as if bound therein and this Addendum shall be so acknowledged by the bidder in his Bid. This Addendum shall take precedence over any conflicting stipulations.

This Addendum is being emailed to each person or firm recorded by the Architect as having received the documents and will also be available for inspection at:

MB Design Associates, Inc.

Persons or firms receiving this Addendum shall be responsible for forwarding the Addendum information to sub-contractors, suppliers, etc. with whom they are working, since such sub-contractors and suppliers may not be recorded by the Architect.

The north, east and west sides of the cupola are to be framed with 1-5/8" metal studs and 5/8" gyp bd – return to windows to create jamb. Frame walls flush with girder truss (adjust metal studs size accordingly). Encase existing sprinkler pipe on south wall flush with balance of existing wall. Exhaust roof penetration is not in correct location on the mechanical plan. Contractor to verify actual location in field.

Jill Maraist