



ELECTRICAL LEGEND	
* GC TO RE-COUNT ALL RE-USABLE EXISTING LIGHT FIXTURE, PROVIDE NEW IF NOT WORKING CONDITION.	
	EXISTING 2x4 FLUORESCENT INDIRECT LIGHT FIXTURE TO REMAIN
	EXISTING 2x2 FLUORESCENT INDIRECT LIGHT FIXTURE TO REMAIN
	NEW TO MATCH EXISTING
	EXISTING FIXTURE TO BE RELOCATED
	EXISTING 2x2 PARABOLIC LIGHT FIXTURE TO REMAIN
	NEW DOWNLIGHT WITH DIMMER
	EXISTING DOWNLIGHT TO REMAIN
	EXISTING 2x4 FRISMAIC FIXTURE TO BE REPLACED WITH NEW OR REPLACED WITH NEW BULBS AT 1ST AND 2ND FLOORS IN STAIRCASE
	EXISTING WALL SCONE TO BE REPLACED WITH NEW OR REPLACED WITH NEW BULBS AT 1ST AND 2ND FLOORS IN LANDINGS
	EXIT SIGN WITH 90 MIN BATTERY BACK UP
	EXIT SIGN WITH DIRECTIONAL ARROW WITH 90 MIN BATTERY BACK UP
	WALL MOUNTED EMERGENCY LIGHT WITH 90 MIN BATTERY BACK UP
	EXIT SIGN/EMERGENCY LIGHT COMBO WITH 90 MIN BATTERY BACK UP
	SWITCH WITH OCCUPANCY SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	3 WAY SWITCH WITH OCCUPANCY SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	DIMMER SWITCH WITH OCCUPANCY SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	MOTION SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	EXHAUST FAN MOTOR
	EXHAUST FAN GRILL
	DISCONNECT
	SIMPLEX RECEPTACLE
	DUPLEX RECEPTACLE
	DUPLEX RECEPTACLE CEILING MOUNTED
	SWITCHED DUPLEX RECEPTACLE
	QUADRUPLEX RECEPTACLE
	SPECIAL RECEPTACLE
	JUNCTION BOX
	FLOOR DUPLEX RECEPTACLE
	FLOOR QUADRUPLEX RECEPTACLE
	POWER POLE
	TELEPHONE JACK
	DATA JACK
	TELEPHONE/DATA JACK
	FLOOR TELEPHONE/DATA JACK
	FLOOR TELEPHONE JACK
	FLOOR DATA JACK
	TV CABLE OUTLET
	SMOKE DETECTOR/CARBON MONOXIDE SENSOR UL LISTED COMBO
	SMOKE DETECTOR
	MULTI-CANDELA FIRE STROBE
	MULTI-CANDELA SPEAKER/STROBE
	PULL STATION
	ELECTRICAL PANEL
	GROUND FAULT INTERRUPT
	NIGHT LIGHT ON 24/7
	NEW
	EXISTING
	EXISTING RELOCATED

SOME SYMBOLS MAY NOT BE USED.

REVISION

OTRISCHMANN DUMALA ARCHITECTURAL GROUP, 2015. THIS DOCUMENT IS THE PROPERTY OF ARCHITECTURAL GROUP. ANY REUSE OR REPRODUCTION WITHOUT THE WRITTEN CONSENT OF TRIESCHMANN DUMALA ARCHITECTURAL GROUP.

PETMEDS
420 SOUTH CONGRESS AVE, SUITE 100
DELRAY BEACH, FL
ELECTRICAL KEY PLAN

TRIESCHMANN DUMALA
architectural group
6451 East Rogers Circle | Suite 9 | Boca Raton | FL 33487
P: 561.981.8916 F: 561.981.8916
www.tdarchgroup.com
AA-26002252
AA-26002244

Seal
Michael W. Dumala, P.E.
Florida License No. AR 91003

Drawn
Date
E1.0

loucks engineering inc.
consulting engineers
E. PALM W. P.E. FL REG 49832
4520 ne 18th ave ste. 400, Ft. Lauderdale, FL 33334
TEL. (954) 938-1881 FLA. REG. #EB-0003306

E1 ELECTRICAL KEY PLAN
1"=20'