



ELECTRICAL LEGEND	
	EXISTING 2x4 FLUORESCENT INDIRECT LIGHT FIXTURE TO REMAIN
	EXISTING 2x2 FLUORESCENT INDIRECT LIGHT FIXTURE TO REMAIN
	NEW TO MATCH EXISTING
	EXISTING FIXTURE TO BE RELOCATED
	EXISTING 2x2 PARABOLIC LIGHT FIXTURE TO REMAIN
	NEW DOWNLIGHT WITH DIMMER
	EXISTING DOWNLIGHT TO REMAIN
	EXISTING 2x4 PRISMATIC FIXTURE TO BE REPLACED WITH NEW OR REPLACED WITH NEW BULBS AT 1ST AND 2ND FLOORS IN STAIRCASE
	EXISTING WALL SCONCE TO BE REPLACED WITH NEW OR REPLACED WITH NEW BULBS AT 1ST AND 2ND FLOORS IN LANDINGS
	EXIT SIGN WITH 90 MIN BATTERY BACK UP
	EXIT SIGN WITH DIRECTIONAL ARROW WITH 90 MIN BATTERY BACK UP
	WALL MOUNTED EMERGENCY LIGHT WITH 90 MIN BATTERY BACK UP
	EXIT SIGN/EMERGENCY LIGHT COMBO WITH 90 MIN BATTERY BACK UP
	SWITCH WITH OCCUPANCY SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	3 WAY SWITCH WITH OCCUPANCY SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	DIMMER SWITCH WITH OCCUPANCY SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	MOTION SENSOR THAT SHALL TURN LIGHTING OFF WITHIN 30 MINUTES OF AN OCCUPANT LEAVING A SPACE
	EXHAUST FAN MOTOR
	EXHAUST FAN GRILL
	DISCONNECT
	SIMPLEX RECEPTACLE
	DUPLEX RECEPTACLE
	DUPLEX RECEPTACLE CEILING MOUNTED
	SWITCHED DUPLEX RECEPTACLE
	QUADRUPEX RECEPTACLE
	SPECIAL RECEPTACLE
	JUNCTION BOX
	FLOOR DUPLEX RECEPTACLE
	FLOOR QUADRUPEX RECEPTACLE
	POWER POLE
	TELEPHONE JACK
	DATA JACK
	TELEPHONE/DATA JACK
	FLOOR TELEPHONE/DATA JACK
	FLOOR TELEPHONE JACK
	FLOOR DATA JACK
	TV CABLE OUTLET
	SMOKE DETECTOR/CARBON MONOXIDE SENSOR UL LISTED COMBO
	SMOKE DETECTOR
	MULTI-CANDELA FIRE STROBE
	MULTI-CANDELA SPEAKER/STROBE
	PULL STATION
	ELECTRICAL PANEL
	GROUND FAULT INTERRUPT
	NIGHT LIGHT ON 24/7
	NEW
	EXISTING
	EXISTING RELOCATED

SOME SYMBOLS MAY NOT BE USED.

REVISION

TRIESCHMANN DUMALA ARCHITECTURAL GROUP, 2010, HAS CONDUCTED A VISUAL OCCUPANCY ANALYSIS OF THIS PROJECT. THE ANALYSIS WAS CONDUCTED IN ACCORDANCE WITH THE 2010 IBC. THE ANALYSIS WAS CONDUCTED BY THE ARCHITECTURAL GROUP AND IS NOT BEING PROVIDED WITHOUT THE ARCHITECT'S CONSENT. SEE THE ARCHITECTURAL GROUP'S WEBSITE FOR MORE INFORMATION.

PETMEDS
 420 SOUTH CONGRESS AVE., SUITE 100
 DELRAY BEACH, FL
ELECTRICAL LIGHTING PLAN

TRIESCHMANN DUMALA
 architectural group
 6451 East Rogers Circle | Suite 9 | Boca Raton, FL 33487
 P: 561.981.8000 F: 561.981.8916
 www.tdarchgroup.com
 AA25002252
 AA25002244

Michael W. Dumala, AIA
 Florida License No. AC 25002244

loucks engineering inc.
 consulting engineers
 E. PALM J. P.E. FL REG. 49832
 4520 N.E. 18th Ave. Ste. 400, Ft. Lauderdale, FL 33334
 TEL. (954) 938-1981 FLA. REG. #EB-0003306

E2.2 ELECTRICAL LIGHTING PLAN

3/16" = 1'-0"

Drawn
 Date
E2.2

JOB # 1690