



2ND FLOOR POWER PLAN
SCALE: 1/4" = 1'-0"



ELECTRICAL SYMBOL LEGEND	
	RECEPTACLE DUPLEX 120V
	SWITCHED RECEPTACLE
	RECEPTACLE CEILING
	FLOOR RECEPTACLE
	QUAD RECEPTACLE
	220V RECEPTACLE
	DISCONNECT SWITCH
	ELECTRICAL PANEL
	COMPUTER/PHONE JACK
	WEATHER PROOF
	GROUND FAULT CURRENT INTERRUPTER
	JUNCTION BOX
	2'x4' LIGHT FIXTURE
	CEILING MOUNTED LIGHT FIXTURE
	WALL MOUNTED LIGHT FIXTURE
	HI HATS
	EMERGENCY LIGHT WITH BATTERY BACK UP.
	EXIT LIGHT WITH BATTERY BACK UP. NOT MORE THAN SW PER FACE.
	COMBO EMERGENCY/EXIT LIGHT WITH BATTERY BACK UP. NOT MORE THAN SW PER FACE.
	EXHAUST FAN
	SWITCH
	3 WAY SWITCH
	4 WAY SWITCH
	TIME CLOCK BYPASS SWITCH (MAX 4 HOURS OVERRIDE)
	OCCUPANT SENSOR. TURNS LIGHTS OFF WITHIN 30 MINUTES AFTER OCCUPANT LEAVES SPACE. WHEN MULTIPLE OCCUPANT SENSORS ARE USED ON ONE LIGHTING CIRCUIT, ANY OCCUPANT SENSOR ACTIVATION WILL TURN ON LIGHTS FOR THAT LIGHTING CIRCUIT FOR 30 MINUTES MAXIMUM.
	ULTRASONIC CEILING MOUNTED OCCUPANCY SENSOR. TURNS LIGHTS OFF WITHIN 30 MINUTES AFTER OCCUPANT LEAVES SPACE. WHEN MULTIPLE MOTION SENSORS ARE USED ON ONE LIGHTING CIRCUIT, ANY OCCUPANCY SENSOR ACTIVATION WILL TURN ON LIGHTS FOR THAT LIGHTING CIRCUIT FOR 30 MINUTES MAXIMUM.
NOTE: OCCUPANCY SENSOR SHALL BE SELECTED TO PROVIDE FULL COVERAGE FOR THE AREA IT SERVES.	
	PROGRAMMABLE THERMOSTAT
	TESTER
NOTE: ALL RECEPTACLES TO BE @ 15" AFF TO BOTTOM OF RECEPTACLE UNLESS NOTED OTHERWISE OR ABOVE COUNTER. ALL SWITCHES TO BE @ 48" AFF TO TOP OF SWITCH UNLESS NOTED OTHERWISE.	



MEMBER:
AMERICAN
INSTITUTE OF
ARCHITECTS
AA26001907

DeMELLO ARCHITECTURE

911 Southwest 18 Street, Boca Raton, Florida 33486
954 671 0203 Fax 954 418 0022

All ideas and designs indicated or repeated on drawings are the property of DeMello Architecture and were created and developed for use in connection with the specific project. None of such ideas and designs shall be used by or disclosed to any person or corporation for any purpose whatsoever without written permission of this office.

SECOND FLOOR ADDITION FOR
DIXIE DIVERS
455 U.S. HIGHWAY #1
DEERFIELD BEACH, FL.

drawing name:

revisions

designed H. DeMello
drawn H. DeMello
date AUG. 21, 2015
scale AS SHOWN
project # 15.138
sheet

BUCHANAN P.E CONSULTING INC.
ELECTRICAL * MECHANICAL * PLUMBING
ENGINEERING
6191 W. ATLANTIC BLVD, SUITE # 2 MARGATE, FL 33063
Ph: 954-990-3200 Fax: 954-990-5232
Email: BUCHANAN@PEENGINEERS.COM
CERTIFICATE OF AUTHORIZATION # 8842
□ RAJA BUCHANAN P.E # 48916 □ MAURICE LORD P.E # 72550

SEAL
DATE: _____