

Luminaire Schedule										
Project: GOODWILL VERO - INTERIOR - REV2 --- AUG - 1 - 2016										
Symbol	Qty	Label	Description	Lumens/Lamp	LLD	LDD	BF	LLF	Lum. Watts	Total Watts
☐	44	D1	HE WILLIAMS GL-4-632-WD-EB3_3-UNV	2800	0.900	0.900	0.880	0.713	170	7480

Calculation Summary					
Project: GOODWILL VERO - INTERIOR - REV2 --- AUG - 1 - 2016					
Label	Avg	Max	Min	Avg/Min	Max/Min
RECEIVING AREA_Workplane	29.03	44	13	2.23	3.38
RETAIL AREA_Workplane	33.59	52	18	1.87	2.89

LPD Area Summary			
Project: GOODWILL VERO - INTERIOR - REV2 --- AUG - 1 - 2016			
Label	Area	Total Watts	LPD
RECEIVING AREA_LPD	4822	2380	0.494
RETAIL AREA_LPD	8921	5100	0.572

