

- KEY NOTES:
- ① BALANCE O/A TO 70 CFM.
 - ② BALANCE O/A TO 55 CFM.
 - ③ HEADER ONLY.
 - ④ FOR HOOD DRAWINGS, ROOF EXHAUST FAN, LOCATIONS AND DUCTWORK ROUTING REFER TO HOOD CONSULTING DRAWINGS, HOODS BY OTHERS.
 - ⑤ FOR HOOD DRAWINGS, ROOF EXHAUST FAN, MUA UNIT LOCATIONS AND DUCTWORK ROUTING REFER TO HOOD CONSULTING DRAWINGS, HOODS BY OTHERS.
 - ⑥ NOT USED
 - ⑦ REFER TO KITCHEN CONSULTANT DRAWINGS FOR ALL WORK IN THIS AREA.
 - ⑧ CONTRACTOR SHALL CONFIRM ALL CLOTHES DRYER VENTING REQUIREMENTS WITH MANUFACTURER INSTRUCTIONS AND SPECIFICATIONS.
 - ⑨ MOTORIZED DAMPERS TO BE INTERLOCKED WITH HOOD. DAMPERS TO CLOSE WHEN HOOD IS ENERGIZED.
 - ⑩ 16x16 EA DUCT UP. MOTORIZED DAMPER SHALL BE NORMALLY CLOSED AND OPEN WHEN HOOD MAKEUP AIR FAN IS ACTIVATED.

MECHANICAL CONTRACTOR TO INTERLOCK RTU-2 WITH BOTH KITCHEN HOODS EXHAUST FAN. RTU-2 SHALL BE ON WHEN HOOD 1 OR HOOD 2 EXHAUST FAN IS ON.

HOOD COMPANY SHALL PROVIDE TEMPERED MUA FOR THE HOOD AS REQUIRED PER FM 2014 CODE.

4 FIRST FLOOR MECHANICAL PLAN
SCALE: 1/8" = 1'-0"

PRIOR TO SUBMITTING THE BID, THE CONTRACTOR SHALL FIELD VERIFY ALL EXISTING CONDITIONS AND INFORM THE ARCHITECT AND THE ENGINEER OF ANY DISCREPANCY BETWEEN THESE DOCUMENTS AND THE EXISTING CONDITIONS AND SHALL INCLUDE IN THE BID TO CORRECT THE SAME AS DIRECTED. THE ENGINEER AND THE ARCHITECT, ARE NOT RESPONSIBLE FOR ANY ADDITIONAL COSTS RESULTING FROM VERIFIABLE EXISTING CONDITIONS DISCOVERED AFTER CONTRACT HAS BEEN AWARDED. NO CHANGES SHALL BE MADE TO THESE PLANS WITHOUT PRIOR APPROVAL FROM THE ENGINEER OF RECORD. ALL CHANGES SHALL BE SUBMITTED FOR REVIEW PRIOR TO INSTALLATION. NOT FOR BID UNTIL PERMIT HAS BEEN ISSUED.

207 SIXTH STREET
WEST PALM BEACH, FLORIDA 33401
PH: 561.684.6844 • gliddenspina.com
FL Lic # AB000297



Architecture • Interior Design
Keith M. Spina # AR13419

New Building For:
OPPORTUNITY INC.
EARLY LEARNING CENTER
4171 Westgate Avenue
Palm Beach County, Florida

THESE DRAWINGS ARE FOR THE EXCLUSIVE USE OF GLIDDEN SPINA + PARTNERS, INC. AND MAY NOT BE DUPLICATED, REPRODUCED OR USED IN ANY MANNER WITHOUT THE EXPRESS WRITTEN CONSENT OF GLIDDEN SPINA + PARTNERS, INC. ALL RIGHTS RESERVED.


Revisions:

Project no: 15435
Date: 09.09.16
Drawn by: RB/SK/JS
Project Architect: BJ

PERMIT / BID SET: 09/07/16



700 WEST HILLSBORO BLVD. - BLDG. #1, SUITE 204
DEERFIELD BEACH, FLORIDA 33441
TEL: (561) 391-9292 FAX: (561) 391-9898
CERTIFICATE OF AUTHORIZATION NO. 28107
LIRELLA IARFATE, P.E. LICENSE #73122
STEPHEN F. ROLLIN, P.E. LICENSE #36428
DONALD H. AUSTIN, JR., PE LICENSE #60651
JASON BARBER, P.E. LICENSE #73050
E-MAIL: INFO@FAECONSULTING.COM
DESIGNED BY: BJ/SK/JS PM: BJ P/N 15434



M1.1

09.09.16 BID/PERMIT

FIRST FLOOR MECHANICAL PLAN