

## ELECTRICAL NOTES

- ALL WORK SHALL BE DONE IN STRICT ACCORD WITH ALL CODES ADOPTED BY ALL AGENCIES HAVING JURISDICTION OVER THE PROJECT TO THE APPROVAL OF THE ARCHITECT.
- ALL WORK TO BE PERFORMED BY QUALIFIED ELECTRICIANS IN ACCORDANCE WITH BOTH LOCAL AND NATIONAL ELECTRICAL CODES.
- ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR ALL PHONE/DATA CONDUIT AND BOXES, WIRING, PLATES AND DEVICES IS THE RESPONSIBILITY OF THE OWNER.
- ALL CONDUCTORS SHALL BE COPPER, UNLESS NOTED OTHERWISE.
- ALL OFFICES SHALL BE MADE WITH APPROVED PRESSURE TYPE CONNECTORS WITH FIELD APPLIED INSULATION THAT EQUALS, OR EXCEEDS, FACTORY APPLIED INSULATION.
- THE COMPLETE ELECTRICAL SYSTEM SHALL BE GROUNDED IN ACCORDANCE WITH NEC, ART. 250.
- ALL MATERIALS SHALL BE NEW THESE MATERIALS (EXCEPT LAMPS AND CORDS) AND ALL WORKMANSHIP SHALL BE GUARANTEED FOR A PERIOD OF ONE YEAR FROM DATE OF FINAL ACCEPTANCE.
- ELECTRICAL CONTRACTOR SHALL REVIEW ALL OTHER DOCUMENTS OF THIS PROJECT AND COORDINATE HIS WORK WITH ALL OTHER TRADES, TO ASSURE A COMPLETE AND WORKABLE ELECTRICAL SYSTEM.
- MINIMUM WIRE SIZE SHALL BE #12 AWG, UNLESS NOTED OTHERWISE. WIRE SIZE #10 AWG, AND LARGER, SHALL BE STRANDED.
- WIRE SIZE #10 AWG, AND SMALLER, SHALL HAVE THIN INSULATION. WIRE SIZE #10 AWG, AND LARGER, SHALL HAVE THIN INSULATION.
- ALL CONDUCTORS SHALL BE INSTALLED IN CONDUIT PER CODE. THE USE OF MC FLEX CABLE SHALL BE PERMITTED IF ALLOWED BY CODE.
- ALL FIXTURES SHALL BE FURNISHED AND INSTALLED COMPLETE WITH NEW LAMPS, UNLESS NOTED OTHERWISE.
- THE ELECTRICAL DESIGN SHOWN IS INTENDED TO BE COMPLETE AND A WORKABLE ELECTRICAL SYSTEM IN ACCORDANCE WITH APPLICABLE CODES. ALL MISCELLANEOUS PARTS, WHETHER SHOWN OR NOT, SHALL BE INCLUDED. ANY DISCREPANCIES IN DRAFTING OR OMISSIONS SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT, OR ENGINEER, PRIOR TO BID OR THEY SHALL BE CONSIDERED TO BE INCLUDED.
- ELECTRICAL CONTRACTOR TO PROVIDE REQUIRED ELECTRICAL FOR CONDENSATE PUMPS. COORDINATE WITH MECH. CONTRACTOR.
- ELECTRICAL CONTRACTOR SHALL COMPLY WITH FBC ENERGY CONSERVATION CODE 260/CHAPTER 9, ALL SECTIONS.
- FEEDERS AND CUSTOMER OWNED SERVICE CONDUCTORS SHALL BE SIZED FOR A MAXIMUM VOLTAGE DROP OF 2 PERCENT AT DESIGN LOAD.
- BRANCH CIRCUIT CONDUCTORS SHALL BE SIZED FOR A MAXIMUM VOLTAGE DROP OF 3 PERCENT AT DESIGN LOAD.
- ELECTRICAL BRANCH CIRCUITS WITHIN PATIENT CARE, TREATMENT AND EXAM AREAS, INCLUDING EXAMINATION TABLES AND/OR CHAIRS, SHALL BE FURNISHED WITH REDUNDANT GROUNDING FOR CIRCUITS PER NATIONAL ELECTRICAL CODE ARTICLE 91B.
- RECESSED LUMINAIRES INSTALLED IN THE BUILDING'S THERMAL ENVELOPE SHALL BE SEALED TO LIMIT AIR LEAKAGE BETWEEN CONDITIONED AND UNCONDITIONED SPACES. ALL RECESSED LUMINAIRES SHALL BE IC-RATED AND LABELED AS HAVING AN AIR LEAKAGE RATE OF NOT MORE THAN 2.0 CFM WHEN TESTED IN ACCORDANCE WITH ASTM E 283 AT A 1.5 PSI PRESSURE DIFFERENTIAL. ALL RECESSED LUMINAIRES SHALL BE SEALED WITH A GASKET OR CAULK BETWEEN THE HOUSING AND INTERIOR WALL OR CEILING COVERING.

## ELECTRICAL LEGEND

|  |   |
|--|---|
|  | DUPLEX RECEPTACLE   |
|  | QUAD RECEPTACLE   |
|  | PHONE/DATA OUTLET 1500 BOX WITH SINGLE RING WITH 1" CONDUIT STUBBED INTO ACCESSIBLE CEILING SPACE WITH ELL. CONNECTOR AND BUSHING ALL MUST HAVE WIRE PRIOR TO C.O.                |
|  | JUNCTION IN CEILING OR WALL AS SHOWN ON SHEETS A2 & A4. MAX. TOTAL 50W THERE ARE EXISTING JUNCTIONS IN THE CEILING. USE AS MANY CLOSEST EXISTING JUNCTIONS AS POSSIBLE.           |
|  | DISCONNECT  |
|  | TV OUTLET<br>VERIFY IF WALL OR CEILING MOUNTED TV'S. FURNISH & INSTALL BACKING FOR WALL OR CEILING MOUNTED TV'S. COORDINATE MOUNTING TYPE, LOCATION, SUPPORT AND HEIGHT W/ TENANT |
|  | STANDARD DUPLEX OUTLET AT SPECIFIED HEIGHT, OFF FINISHED FLOOR TO CENTER OF OUTLET, OUTLET TO BE WIRED TO SINGLE POLE SWITCH.   |
|  | FLUSH FLOOR DUPLEX ELECTRICAL RECEPTACLE W/ VOICE & DATA OUTLET AND FLUSH COVER   |
|  | WALL SWITCH   |
|  | PANEL   |
|  | CIRCUIT NUMBER  |

## KEY NOTES

- DOOR BELL UNDER COUNTERTOP - CHIME IN LAB ROOM #16. VERIFY WITH TENANT/OWNER
- DOORBELL CHIME TO BE SELECTED BY TENANT/OWNER

## BRANCH CIRCUIT VOLTAGE DROP ON 120V (MAX ALLOWABLE 3%)

| AMPS | 14' MAX LENGTH (1/2" COND) | 15' MAX LENGTH (1/2" COND) | 16' MAX LENGTH (1/2" COND) | 17' MAX LENGTH (1/2" COND) | 18' MAX LENGTH (1/2" COND) |
|------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| 15   | 55'                        | 90'                        | 145'                       | 240'                       |                            |
| 15   | 60'                        | 100'                       | 155'                       | 255'                       |                            |
| 14   | 65'                        | 105'                       | 165'                       | 270'                       |                            |
| 13   | 70'                        | 115'                       | 180'                       | 290'                       |                            |
| 12   | 75'                        | 125'                       | 190'                       | 300'                       |                            |
| 11   | 85'                        | 135'                       | 210'                       | 345'                       |                            |
| 10   | 95'                        | 153'                       | 235'                       | 380'                       |                            |
| 9    | 105'                       | 166'                       | 260'                       | 425'                       |                            |
| 8    | 115'                       | 186'                       | 290'                       | 475'                       |                            |
| 7    | 130'                       | 215'                       | 330'                       | 540'                       |                            |
| 6    | 150'                       | 250'                       | 385'                       | 625'                       |                            |
| 5    | 190'                       | 300'                       | 470'                       |                            |                            |
| 4    | 235'                       | 375'                       | 575'                       |                            |                            |
| 3    | 315'                       | 500'                       | 775'                       |                            |                            |
| 2    | 475'                       | 750'                       | 1170'                      |                            |                            |
| 1    | 950'                       | 1500'                      | 2600'                      |                            |                            |

\* MAX. LOAD ON A 20AMP CIRCUIT

## RISER NOTES

- DISC. SAME SIZE AS BREAKER SERVING SAME - ACCESSIBLE PER CODE
- 2 - #10, 1 #10 GROUND IN 1/2" COND.
- 2 - #10, 1 #10 GROUND IN 1/2" COND.
- 3 - 3/0, #6 GR IN 2" COND.
- ALL EQUIPMENT INTERNALLY CONTROLLED AND PROTECTED
- SLEEVE FOR CONTROL WIRING TO SPACE
- NEMA 3R DISC. SAME SIZE AS BREAKER SERVING SAME
- W/GRF DUPLEX RECEPT FOR COND. EQUIP. VERIFY IF EXIST AND INSTALL IF NOT (ONE IS REQ'D EVERY 20')

## ELECTRICAL PLAN

SCALE: 1/4" = 1'-0"


2185 S.F.

| PANEL: 4  | LOAD DESCRIPTION | WATTS  | BKR  | MLO   | BKR  | WATTS  | LOAD DESCRIPTION |
|---|------------------|--------|------|-------|------|--------|------------------|
| MANUFACTURER: CUTLER HAMMER OR EQ                       | AHU #1           | 116448 | 40/2 | 1 2   | 25/2 | 113536 | AHU #2           |
| UL LISTED NO ALUMINIUM BUSSES                           | CJ #1            | 115616 | 45/2 | 5 6   | 25/2 | 113120 | CJ #2            |
| MIN. 22,000 AIC, SERIES RATED MAIN: MLO                 | LIGHTING         | 11428  | 20/1 | 9 10  | 20/1 | 11647  | LIGHTING         |
| NEMA 3R SURFACE:  | 5 REC. # 180     | 900    | 20/1 | 11 12 | 20/1 | 1260   | 6 REC. # 180     |
| FLUSH: <input checked="" type="checkbox"/> CIRCUITS: 42 | 6 REC. # 180     | 1080   | 20/1 | 13 14 | 20/1 | 1260   | 6 REC. # 180     |
| WIRE: 3 PHASE: 1 AMP: 200                               | 6 REC. # 180     | 1080   | 20/1 | 15 16 | 20/1 | 1440   | 5 REC. # 180     |
| FED FROM: METER CENTER                                  | APPLIANCE        | 1200   | 30/2 | 17 18 | 20/1 | 180    | REFRIG           |
| FEEDER: 3 3/0, 1 #6 GR IN 2" COND                       | 4 REC. # 180     | —      | —    | 19 20 | 20/1 | 1080   | 6 REC. # 180     |
| REMARKS:  | WATER HEATER     | 3500   | 30/2 | 21 22 | 20/1 | 900    | 5 REC. # 180     |
| 23,733 WATTS  | 6 REC. # 180     | 1080   | 20/1 | 23 24 | 20/1 | 1260   | 6 REC. # 180     |
| 11,661 25% LARGEST MOTOR LOAD                           | PHONE            | 500    | 20/1 | 27 28 | 20/1 | 120    | 4 REC. # 180     |
| 36,284 TOTAL CALC. WATTS                                | 5 REC. # 180     | 900    | 20/1 | 29 30 | 20/1 | 600    | EWC              |
| 200 = 114 AMP   | SPACE            | —      | 20/1 | 31 32 | 20/1 | —      | SPACE            |
|   | SPACE            | —      | —    | 33 34 | —    | —      | SPACE            |
|   | SPACE            | —      | —    | 35 36 | —    | —      | SPACE            |
|   | SPACE            | —      | —    | 37 38 | —    | —      | SPACE            |
|   | SPACE            | —      | —    | 39 40 | —    | —      | SPACE            |
|   | SPACE            | —      | —    | 41 42 | —    | —      | SPACE            |
|   | TOTAL WATTS      | 23,733 |      |       |      | 11,661 | TOTAL WATTS      |

\* INCLUDES CONT. USE FACTOR (25%)  
\*\* VERIFY WITH NAMEPLATE DATA AND RECALCULATE AS REQUIRED

## PANEL SCHEDULE

IT IS THE CLIENT'S RESPONSIBILITY TO VERIFY ALL OUTLET HEIGHTS &amp; LOCATIONS WITH GENERAL CONTRACTOR EQUIPMENT SUPPLIER AND/OR MANUFACTURER

MB DESIGN ASSOCIATES, INC.  
FLORIDA LICENSE #: AA26000521P.O. Box 4376  
Tequesta, Florida 33469  
phone: (561) 222-2893  
email: tjmarais@aol.com

WILLIAM TRACY, #A0014756

DATE:

THE FOLLOWING CODES WERE USED IN THE DESIGN OF THIS PROJECT:

2014 FLORIDA BUILDING CODE  
EXISTING BUILDING, BUILDING, PLUMBING, FUEL GAS, MECHANICAL, TEST PROTOCOLS FOR HIGH VELOCITY HURRICANE ZONES, ACCESSIBILITY AND ENERGY

2011 NATIONAL ELECTRICAL CODE NFPA 70

FLORIDA FIRE PREVENTION CODE, 5TH EDITION (INCLUDING NFPA 1, 2012 AND 101, 2012 EDITION) WITH FLORIDA AMENDMENTS

PROJECT NAME/LOCATION:

## ADVANCED VISION CARE

DR. AMIR CUKIERMAN, O.D.

3893 MILITARY TRAIL  
SUITE #4  
ADMIRAL'S CROSSING  
JUPITER, FL

I (WE) HAVE REVIEWED THESE DRAWINGS, UNDERSTAND THE WORK OUTLINED THEREON, AND HEREBY APPROVE SAME FOR CONSTRUCTION.

BY:

DATE:

THESE DRAWINGS ARE BASED ON EXISTING DRAWINGS WHEN AVAILABLE. FIELD INSPECTION OF AS BUILT CONDITIONS AND OTHER INFORMATION FROM THE BUILDING OWNER, MAINTENANCE DEPARTMENT AND AS NOTED. INFORMATION WAS GATHERED WITHOUT "DESTRUCTIVE INVESTIGATION" (CUTTING INTO EXISTING SURFACES TO REVEAL STRUCTURE, PIPING, DUCTWORK, ETC). CONTRACTORS AND SUBCONTRACTORS ARE TO BASE BIDS ON INFORMATION SHOWN. SHOULD CONSTRUCTION REVEAL THAT EXISTING CONDITIONS ARE NOT AS ANTICIPATED OR AS SHOWN ON THESE DRAWINGS THE CONTRACTOR AND/OR SUBCONTRACTORS WILL NOTIFY THE OWNER/OWNER'S REPRESENTATIVE OF THE DIFFERENCE AND THE PRICE WILL BE ADJUSTED UP OR DOWN TO REFLECT THE DISCREPANCY.

JOB #: DR CUKIERMAN

DATE: 3/16/2016

SCALE: VARIES

DRAWN BY: JM

ISSUED:

REVISIONS:

SHEET NO:

E - 2

OF 2

## ELECTRICAL RISER

