



1683 N.E. JENSEN BEACH BLVD.
JENSEN BEACH, FLORIDA 34957

PHONE: 772-283-6032
FAX: 772-283-8150

June 9, 2016

Dr. Vakani Orthodontist Office
2196 Gatlin Blvd

RFI RESPONSE #2

Flooring [Finishes- the Floor Finishes indicated in the Floor Finish Schedule on Sheet A1 are correct. The Owner will be providing floor finishes and wall tile. GC is responsible for installation as well as receipt of delivery indicated in the Floor Finish Notes. The carpet will be a glue down for now, I am waiting for confirmation from the Dr. The GC is responsible for interior and exterior painting and supplies. *Painting*

Sheet E2 has a symbol of an S in a circle that is not indicated in the Legend. This symbol is a speaker location.

all Bathroom Scones are fixture "F8" as indicated on the Electrical Plan and Lighting Equipment Schedule.

Electric There is NO fire alarm.

Transformer Location – Please see Civil Sheet 8 Detail "E". The transformer pad and transformer location are adjacent to the lift station. This location is preliminary and may be subject to change but should be used for bidding purposes.

Electrical Details for Grinder – See Civil Sheet 9 for grinder information & details.

All questions shall be addressed thru the Architect in writing using the following contact information:

Stewart Granfield - NCARB
President - Managing Architect
Granfield Architects PLLC
1683 NE Jensen Beach Blvd.
Jensen Beach, Fl. 34957
(772)283-6032 office
(772)283-8150 fax
stewart@granarch.comcastbiz.net