

June 13, 2016

Dr. Vakani Orthodontist Office 2196 Gatlin Blvd

RFI RESPONSE #3

The carpet has been confirmed as glue down by the Doctor.

Flooring.

The receptacles shall be Hospital Grade in patient areas, OP 1-7 and TC1-3.

ELECTRIC

All questions shall be addressed thru the Architect in writing using the following contact information:

Stewart Granfield - NCARB
President - Managing Architect
Granfield Architects PLLC
1683 NE Jensen Beach Blvd.
Jensen Beach, Fl. 34957
(772)283-6032 office
(772)283-8150 fax
stewart@granarch.comcastbiz.net