



1683 N.E. JENSEN BEACH BLVD.  
JENSEN BEACH, FLORIDA 34957  
PHONE: 772-283-6032  
FAX: 772-283-8150

May 26, 2016

Dr. Vakani Orthodontist Office  
2196 Gatlin Blvd

## **RFI RESPONSE #1**

MC cables may be used for non-home runs. Hospital grade MC is permitted.

The Accessory Building is a grey box, no Electrical, No Plumbing, No Mechanical, No Slab, No Ceiling is provided. For Accessory Building Exterior Sconces, GC is responsible for providing j-boxes and conduit stub-out to interior for Future Sconces. See Exterior Elevations for sconce locations. Site Lighting locations are indicated in the Civil Drawings.

Site Lighting Fixture cut sheets are provided in the product file attached to this clarification. The Owner would like the Dark Platinum finish.

The Fixtures F11, F14, and SW7 are Owner provided fixtures, GC is responsible for installation.

Specification for Aluminum Wall Panels: Dri-Design Aluminum Siding System w/ Kynar Paint finish to match standing seam metal roof. NOA: 14-0731.08  
Wall Sheathing will be 5/8" plywood sheathing in lieu of 1/2".

Floor Finishes- the Floor Finishes indicated in the Floor Finish Schedule are correct. The bid invitation is incorrect. The Owner will be providing Floor Finishes and GC is responsible for installation as well as receipt of delivery indicated in the Floor Finish Notes.

Exterior Door & Window Frames: The frames should be clear anodized mill finish.

Location of Sod and Irrigation questions should be sent to EDC.  
Sod should be floratam, ignore St. Augustine grass note provided in General Notes Sheet A2.

All questions shall be addressed thru the Architect in **writing** using the following contact information:

Stewart Granfield - NCARB  
President - Managing Architect  
**Granfield Architects PLLC**  
1683 NE Jensen Beach Blvd.  
Jensen Beach, Fl. 34957  
(772)283-6032 office  
(772)283-8150 fax  
[stewart@granarch.com](mailto:stewart@granarch.com)  
[castbiz.net](http://castbiz.net)