


2ND FLOOR LIGHTING PLAN
SCALE: 1/4" = 1'-0"




LIGHTING FIXTURE SCHEDULE							
SYMBOL	LABEL	TYPE OF FIXTURE	FINISH	LENS TYPE	VOLT	LAMP	MANUFACTURER & MODEL NO.
⎓	A	4' 2L Paralineer Fluorescent - 4' Cable	WHITE	LDUVER	-	(2) F32T8/35K	LSI # 482-ACK4-232-16-SSO-CAN
⊙	B	Wall Mounted Incand. Fixt.			-		(as approved by owner)
⊙	C	Wall Mounted Exterior Incand. Fixt.					(as approved by owner)
⊕	EXIT EM	Combination EM / Exit	WHITE	RED LETTERS	-	L.E.D.	LSI # EMEX 1/2 R W 120/277
⊕	EM	Emergency Lt.	WHITE			L.E.D.	LSI # EM
⊕	EXIT	EXIT LIGHT WITH BATTERY BACK UP, NOT MORE THAN 5W PER FACE.	WHITE	RED LETTERS		L.E.D.	

NOTE 1: VERIFY CEILING TYPES PRIOR TO ORDERING

FBC-2014 - ENERGY CONSERVATION INTERIOR LIGHTING POWER ALLOWANCE CALCULATIONS -				
SPACE TYPE	ALLOWED (W/SQ FT)	AREA (SQ FT)	ALLOWED (W)	USED (W)
OFFICE	0.9 W/SQ.FT	x 1734 SQ.FT	= 1561 WATT	1472 WATT
TOTALS			1561 WATT	1472 WATT

BUCHANAN P.E CONSULTING INC.
ELECTRICAL * MECHANICAL * PLUMBING
ENGINEERING
6191 W. ATLANTIC BLVD, SUITE # 2 MARGATE, FL 33063
Ph: 954-990-3300 Fax: 954-990-5232
Email: BUCHANAN@PEENGINEERS.COM
CERTIFICATE OF AUTHORIZATION # 8842
□ RAJA BUCHANAN P.E # 48916 □ MAURICE LORD P.E # 72550



MEMBER:
AMERICAN
INSTITUTE OF
ARCHITECTS
AA26001907

DeMELLO ARCHITECTURE
911 Southwest 18 Street, Boca Raton, Florida 33486
954 671 0203 Fax 954 418 0022

All ideas and designs indicated or referred to in this drawing are the property of DeMello Architecture and were created and developed for use in connection with the specific project. None of such ideas and designs shall be used by or disclosed to any person or corporation for any purpose whatsoever without written permission of this office.

SECOND FLOOR ADDITION FOR
DIXIE DIVERS
455 U.S. HIGHWAY #1
DEERFIELD BEACH, FL.

drawing name:

revisions

designed H. DeMello
drawn H. DeMello
date AUG. 21, 2015
scale AS SHOWN
project # 15.138
sheet