

LIGHTING COMPLIANCE CERTIFICATE

Florida Energy Efficiency Code For Building Construction
 EnergyGauge Summit® Fla/Com-2010, Effective Date: March 15, 2012 -- Form 506-2010
 Total Building Performance Method for Commercial Buildings

PROJECT SUMMARY	
Short Desc: Immunotek Plasma	Description: Lake Worth FL - Immunotek Bio Center Remodel
Owner: RR Companies	City: Lake Worth
Address1: 4550 Lake Worth Road	State: FL
Address2:	Zip: 34205
Type: Healthcare-Clinic	Class: Renovation to existing building
Jurisdiction: BRADENTON, MANATEE COUNTY, FL (511200)	
Conditioned Area: 14178 SF	Conditioned & UnConditioned Area: 14178 SF
No of Stories: 1	Area entered from Plans: 12038 SF
Permit No: 0	Max Tonnage: 41.3
If different, write in: _____	

Compliance Summary			
Component	Design	Criteria	Result
Gross Energy Cost (in \$)	2,927.0	3,047.0	PASSED
LIGHTING CONTROLS			PASSES
EXTERNAL LIGHTING			No Entry
HVAC SYSTEM			PASSES
PLANT			No Entry
WATER HEATING SYSTEMS			PASSES
PIPING SYSTEMS			No Entry
Met all required compliance from Check List?			Yes/No/NA
IMPORTANT MESSAGE Info 5009 -- -- An input report of this design building must be submitted along with this Compliance Report			

CERTIFICATIONS	
I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code	
Prepared By: _____	Building Official: _____
Date: _____	Date: _____
I certify that this building is in compliance with the Florida Energy Efficiency Code	
Owner Agent: _____	Date: _____
If Required by Florida law, I hereby certify (*) that the system design is in compliance with the Florida Energy Efficiency Code	
Architect: _____	Reg No: _____
Electrical Designer: David Melroy	Reg No: 70395
Lighting Designer: _____	Reg No: _____
Mechanical Designer: Benjamin Yeung	Reg No: 49077
Plumbing Designer: _____	Reg No: _____
(*) Signature is required where Florida Law requires design to be performed by registered design professionals.	

Lighting Controls Compliance						
Acronym	ASHRAE ID	Description	Area (sq.ft)	Design CP	Min CP	Compliance
PrZo1Sp1	1	Electrical Mechanical Equipment Room - General	14,178	16	2	PASSES
PASSES						

EnergyGauge Summit® v5.20
INPUT DATA REPORT


Project Information	
Project Name: Immunotek Plasma	Orientation: North
Project Title: Lake Worth FL - Immunotek Bio Center Remodel	Building Type: Healthcare-Clinic
Address: 4550 Lake Worth Road	Building Classification: Renovation to existing building
State: FL	No. of Stories: 1
Zip: 34205	Gross Area: 14178 SF
Owner: RR Companies	

Zones						
No	Acronym	Description	Type	Area [sf]	Multiplier	Total Area [sf]
1	PrZo1	Zone 1	CONDITIONED	14178.0	1	14178.0

Lighting							
No	Type	Category	No. of Luminaires	Watts per Luminaire	Power [W]	Control Type	No. of Ctrl pts
In Zone: PrZo1							
In Space: PrZo1Sp1							
1	Recessed Fluorescent - No vent	General Lighting	43	96	4128	Central control	4
2	Recessed Fluorescent - No vent	General Lighting	86	64	5504	Central control	8
3	Compact Fluorescent	General Lighting	5	64	320	Central control	1
4	Incandescent	General Lighting	12	24	288	Central control	1
5	Incandescent	General Lighting	24	24	576	Central control	2

ACKAL A PROFESSIONAL CORPORATION
 ARCHITECTS
 105 CHAPEL DRIVE - LAFAYETTE, LOUISIANA 70506
 337-988-5271 ph - 337-988-5272 fax
 www.ackalarchitects.com

INTERIOR TENANT IMPROVEMENT FOR:
 IMMUNOTEK BIO CENTERS, LLC
 4550 LAKE WORTH ROAD
 OFFICE DEPOT PLAZA, SUITE B-5
 LAKE WORTH, PALM BEACH COUNTY, FL 33463



AUG. 02, 2016
COPYRIGHT © 2016 ACKAL ARCHITECTS, APC.
 THIS DOCUMENT IS THE PROPERTY OF
 ACKAL ARCHITECTS, APC.
 THIS DOCUMENT MAY NOT BE COPIED,
 REPRODUCED OR USED WITHOUT
 WRITTEN CONSENT FROM
 ACKAL ARCHITECTS, APC.

proj. no. 16-002
 date: 08-02-2016
 project architect: B.A.
 project manager: A.D.
 drawn by: MSA
 file name: LAKEWORTH
 revised:
 plot scale: AS NOTED
 sheet name:
 LIGHTING COMPLIANCE
 CERTIFICATE



sheet no.
 E0.4
 37 of 42