GENERAL NOTES:

1. COORDINATE THE EXACT MOUNTING LOCATION OF ALL MECHANICAL EQUIPMENT WITH THE MECHANICAL CONTRACTOR.
2. REFER TO SHEET E2.0 FOR THE LOCATION OF ALL PANELS.

SHEET NOTES:

1. EXTEND AND CONNECT CIRCUITING FROM JUNCTION BOX TO OUTLETS IN AREA WITH SAME CIRCUIT NUMBERS, ROUTE #12 CONDUCTORS (MINIMUM) THROUGHOUT, UNLESS NOTED OTHERWISE.
2. PROVIDE WEATHERPROOF MAINTENANCE RECEPTACLE MOUNTED ON 1/2" RGS RISER SECURELY MOUNTED TO ROOF STRUCTURE BELOW.
3. PROVIDE CONNECTION FROM OUTDOOR UNIT TO INDOOR UNIT PER THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.
4. THE CONTRACTOR SHALL PROVIDE CONNECTION FROM OUTDOOR UNIT TO INDOOR UNIT. PROVIDE POWER AND CONTROL CONDUITS AND CONDUCTORS PER THE INSTALLED EQUIPMENT SHOP DRAWINGS. THIS SHALL INCLUDE, BUT IS NOT LIMITED TO 5 #14 CONDUCTORS FROM OUTDOOR CONDENSOR TO INDOOR DEFROST BOX AS WELL AS 2 #14 CONDUCTORS TO UNIT THERMOSTAT.

A / E2.3 **ELECTRICAL ROOF PLAN**
1/8" = 1'-0"

NORTH

ACKAL A PROFESSIONAL CORPORATION
ARCHITECTS
105 CHAPEL DRIVE - LAFAYETTE, LOUISIANA 70506
337-988-5271ph. - 337-988-5272fax
www.ackalarchitects.com

INTERIOR TENANT IMPROVEMENT FOR:
IMMUNOTEK BIO CENTERS, LLC
4550 LAKE WORTH ROAD
OFFICE DEPOT PLAZA, SUITE B-5
LAKE WORTH, PALM BEACH COUNTY, FL 33463

DAVID J. MELROY, III LICENSE No. 76765 STATE OF FLORIDA PROFESSIONAL ENGINEER

AUG. 02, 2016

COPYRIGHT © 2016 ACKAL ARCHITECTS, APC.
THIS DOCUMENT IS THE PROPERTY OF ACKAL ARCHITECTS, APC.
THIS DOCUMENT MAY NOT BE COPIED, REPRODUCED OR USED WITHOUT WRITTEN CONSENT FROM ACKAL ARCHITECTS, APC.

proj. no. 16-002
date: 08-02-2016
project architect: B.A.
project manager: A.D.
drawn by: MSA
file name: LAKEWORTH
revised:
plot scale: AS NOTED

sheet name: ELECTRICAL ROOF PLAN

sheet no. E2.3

MSA #L16029

MSA ENGINEERING CONSULTANTS
370 E. Windmill Lane, Suite 100
Las Vegas, NV. 89123
T: (702) 896-1100
msa-lv.com