



- FOUNDATION PLAN NOTES:**
- FLOOR SLAB SHALL BE 4" THICK CONCRETE REINF W/6x6 W2.1xW2.1 WWF OVER 10 MIL VAPOR BARRIER ON COMPACTED TERMITRE TREATED SUBGRADE. (SEE SLAB ON GRADE DETAILS FOR PLACEMENT OF REINFORCEMENT)
  - T/ SLAB EL = +0'-0", UNO (REFERENCE ONLY) SEE CIVIL FOR ACTUAL ELEVATION
  - T/ WALL FTG. EL. = -2'-0" TYP. U.N.O.
  - T/ STL AND CONC COLS FTG = -2'-0", TYP UNO.
- 8" MASONRY WALLS (ONE STORY):**
- Denotes #5 in grout filled cells at ends, corners, intersections and as shown on plan. SPACED NO GREATER THAN 48" O.C. U.N.O. IN PLAN.
- 8" MASONRY WALLS (FRONT TOWERS AND TWO STORIES):**
- Denotes #6 in grout filled cells at ends, corners, intersections and as shown on plan. SPACED NO GREATER THAN 48" O.C. U.N.O. IN PLAN.
- 8" MASONRY WALLS (PARAPET):**
- Denotes #6 in grout filled cells at ends, corners, intersections and as shown on plan. SPACED NO GREATER THAN 24" O.C. U.N.O. IN PLAN.
- 12" MASONRY WALLS (FRONT TOWER):**
- Denotes #6 in grout filled cells at ends, corners, intersections and as shown on plan. SPACED NO GREATER THAN 40" O.C. U.N.O. IN PLAN.
- ALL FTGS ARE CENTERED BENEATH BRG WALLS AND COLS, TYP UNO.
  - SEE SHT S1.0 FOR GENERAL NOTES.
  - SIDEWALK SLAB = 4" CONCRETE SLAB ON COMPACTED FILL REINFORCED WITH 6x6 W1.4xW1.4 W.W.F., TYP.
  - (2) #4x4'-0" LONG @ 3" O.C. PLACED 2" CLEAR FROM CORNER CENTERED IN SLAB, TYP. AT RE-ENTRANT CORNERS.

SCALE: 1/8"=1'-0"

FOUNDATION PLAN

New Building For:  
**OPPORTUNITY INC.**  
 EARLY LEARNING CENTER  
 4171 Westgate Avenue  
 Palm Beach County, Florida

COPYRIGHT 2016  
 THESE DRAWINGS ARE FOR THE EXCLUSIVE USE OF GLIDDEN SPINA + PARTNERS, INC. AND MAY NOT BE REPRODUCED, COPIED, OR USED IN ANY MANNER WITHOUT THE EXPRESS WRITTEN CONSENT OF GLIDDEN SPINA + PARTNERS, INC. ALL RIGHTS RESERVED.

sheet title:	FOUNDATION PLAN
file name:	
project no:	16024
date:	09/09/16
drawn by:	S.G.
checked by:	P.S.
revisions:	

**JOHNSON STRUCTURAL GROUP**  
 E.B. #00008993  
 MARK JOHNSON, P.E. #9583, SBCB  
 1300 N.W. Boca Raton Blvd., Suite #818  
 Boca Raton, FL 33431  
 (754) 982-8999 (754) 982-8999  
 EMAIL: mark@johnsonstructural.com  
 WWW.JOHNSONSTRUCTURAL.COM

**S2.0**

09.09.16 BID/PERMIT

207 SIXTH STREET  
 WEST PALM BEACH, FLORIDA 33401  
 ph : 561.684.6844 • gliddenspina.com  
 FL Lic. # AA26002399

**GLIDDEN SPINA + PARTNERS**  
 Architecture • Interior Design  
 Keith M. Spina # ARI349