

Date: October 3, 2016

RE: RPB Commons Amphitheatre and Restroom, PR1504&PR1603 – Request for information

Thank you for your interest in the Village's project. Highlighted responses to requests for information are listed below. Please note the list is a compilation of questions submitted from multiple Contractors and Suppliers.

Previous RFI responses and addenda can be viewed at: <http://www.royalpalmbeach.com/Bids>

Sincerely,

Christopher Marsh, P.E.
Village Engineer
Office: (561) 790-5131
Village of Royal Palm Beach
Engineering Department
1050 Royal Palm Beach Boulevard
Royal Palm Beach, FL 33411
cmarsh@royalpalmbeach.com

Sent: Thursday, September 29, 2016 4:17 PM
To: Christopher Marsh
Subject: Royal Palm Beach Amphitheatre and Restrooms project

Good Afternoon,

Would these vanities include backsplash?

Yes, vanity tops should include 4" backsplash (3-sides), same material as tops.

Sent: Thursday, September 29, 2016 3:21 PM
To: Christopher Marsh
Subject: Royal Palm Beach Amphitheatre and Restrooms project

Good Afternoon,

I have a questions regarding the Royal Palm Beach Amphitheatre and Restrooms project.
I see one (1) bathroom floorplan, is it just one?

There are two restroom locations, please refer to site plan. Plans show typical. Restroom locations are mirrors of each other.

We are direct distributors and fabricators, for the vanity tops, do we include material in our proposal or just fabrication, delivery and installation and material will be provided?

The project will be awarded to a single Contractor. Material, fabrication, delivery and installation shall be completed in accordance with plans and specification.

Also, the urinal dividers, will those made out of stone? Should we include those in our bid?

Urinal dividers are made out of 4" CMU with stucco/paint finish. The project will be awarded to a single Contractor. Material, fabrication, delivery and installation shall be completed in accordance with plans and specification.