



**EMERGENCY
PHOTOMETRICS PLAN**
3/16"=1'-0" NORTH

Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
100_Floor	Illuminance	Fc	2.06	3.3	0.9	2.29	3.67
101_Floor	Illuminance	Fc	9.87	22.4	1.2	8.23	18.67
102_Floor	Illuminance	Fc	9.03	34.0	0.5	18.06	68.00
108_Floor	Illuminance	Fc	10.20	23.1	3.6	2.83	6.42
109_Floor	Illuminance	Fc	6.16	20.0	1.5	4.11	13.33
110_Floor	Illuminance	Fc	19.09	42.1	6.6	2.89	6.38
112_Floor	Illuminance	Fc	14.07	29.4	3.3	4.26	8.91
113_Floor	Illuminance	Fc	7.01	26.5	0.8	8.76	33.13
116_Floor	Illuminance	Fc	8.85	32.1	0.8	11.06	40.13
119_Floor	Illuminance	Fc	5.99	19.9	1.1	5.45	18.09
120_Floor	Illuminance	Fc	9.05	22.8	2.0	4.53	11.40
122_Floor	Illuminance	Fc	15.41	36.3	4.2	3.67	8.64
123_Floor	Illuminance	Fc	6.27	27.8	0.6	10.45	46.33
125_Floor	Illuminance	Fc	6.40	25.1	0.4	16.00	62.75
127_Floor	Illuminance	Fc	9.09	29.0	1.1	8.26	26.36
129_Floor	Illuminance	Fc	6.04	32.6	0.4	15.10	81.50
132_Floor	Illuminance	Fc	2.18	2.8	1.6	1.36	1.75
EXTERIOR_1_Floor	Illuminance	Fc	2.16	2.8	1.6	1.35	1.75
EXTERIOR_2_Floor	Illuminance	Fc	2.20	2.8	1.5	1.47	1.87
EXTERIOR_3_Floor	Illuminance	Fc	2.18	2.7	1.5	1.45	1.80
EXTERIOR_Floor	Illuminance	Fc	2.20	2.8	1.6	1.38	1.75
EXTERIOR_Floor_1	Illuminance	Fc	2.13	2.8	1.4	1.52	2.00

ISSUED FOR PERMIT
ISSUED FOR CONSTRUCTION

KAMM CONSULTING PROJECT # 2016-0024
PROJECT MANAGER: JOHN CHIRGWIN

KAMM Consulting
1407 West Newport Center Drive
Deerfield Beach, Florida 33442
Phone 954.949.2200 Fax 954.949.2201
engineering@kammconsulting.com
Certification of Authorization #8189

10.21.16
date
signed

REVISIONS	BY

Slattery & Associates
ARCHITECTS
PLANNERS

2060 NW BOCA RATON BLVD.
SUITE 2
BOCA RATON, FL 33431
TEL: 561-392-3848
FAX: 561-392-5402
WWW.SLATTERYARCHITECTS.COM

ACTIVITY CENTER
FOR
FLORENCE FULLER CHILD DEVELOPMENT CENTERS
WEST CAMPUS
S.W. 185TH STREET
BOCA RATON, PALM BEACH COUNTY, FLORIDA

EMERGENCY PHOTOMETRICS PLAN

BIDDING
NOT FOR
CONSTRUCTION

DATE OF SEAL: 4/2/08

SLATTERY & ASSOCIATES
FLORIDA REGISTRATION # AA0003381

DRAWN	JWC/PG/AE
CHECKED	AK/MP
DATE	10-21-16
SCALE	AS NOTED
JOB NO.	2011-64
SHEET	

E2.1E

PHASE: C.D. SET 10-21-16