



HVAC POWER PLAN
3/16"=1'-0" NORTH

KEY NOTES

- 1 PROVIDE FUSES AS RECOMMENDED BY EQUIPMENT MANUFACTURER.
- 2 MOUNT DISCONNECT ON OR IMMEDIATELY ADJACENT TO EQUIPMENT SERVED. LOCATE DISCONNECT TO PROVIDE WORKING CLEARANCE AND ACCESS AS REQUIRED BY THE NEC.

| | |
|---------------------------|---|
| ISSUED FOR PERMIT | |
| ISSUED FOR CONSTRUCTION | |
| KAMM CONSULTING PROJECT # | 2016-0024 |
| PROJECT MANAGER: | JOHN CHIRGWIN |
| KAMM Consulting | 1407 West Newport Center Drive Deerfield Beach, Florida 33442 Phone 954.949.2200 Fax 954.949.2201 engineering@kammconsulting.com Certification of Authorization #8189 |
| date | 10.21.16 |
| signed | |

| REVISIONS | BY |
|-----------|----|
| | |
| | |
| | |
| | |
| | |

Slattery & Associates
 ARCHITECTS PLANNERS
 2060 NW BOCA RATON BLVD.
 SUITE 2
 BOCA RATON, FL 33431
 TEL: 561-392-3848
 FAX: 561-392-5402
 WWW.SLATTERYARCHITECTS.COM

ACTIVITY CENTER FOR FLORENCE FULLER CHILD DEVELOPMENT CENTERS WEST CAMPUS
 S.W. 185TH STREET
 BOCA RATON, PALM BEACH COUNTY, FLORIDA

BIDDING NOT FOR CONSTRUCTION
 DATE OF SEAL: 4/2/08
 SLATTERY & ASSOCIATES
 FLORIDA REGISTRATION # AA0003381

HVAC POWER PLAN

| | |
|---------|-----------|
| DRAWN | JWC/PG/AE |
| CHECKED | AK/MP |
| DATE | 10-21-16 |
| SCALE | AS NOTED |
| JOB NO. | 2011-64 |
| SHEET | E3.2 |

PHASE: C.D. SET 10-21-16