



ROOF POWER PLAN
 3/16"=1'-0" NORTH

- KEY NOTES**
- ① PROVIDE FUSES AS RECOMMENDED BY EQUIPMENT MANUFACTURER.
 - ② MOUNT DISCONNECT ON OR IMMEDIATELY ADJACENT TO EQUIPMENT SERVED. LOCATE DISCONNECT TO PROVIDE WORKING CLEARANCE AND ACCESS AS REQUIRED BY THE NEC.
 - ③ INSTALL WEATHER PROOF GFI RECEPTACLE ON EQUIPMENT FRAME. AVOID ALL ACCESS PANELS AND CONTROLLERS.

REVISIONS	BY

Slattery & Associates
 ARCHITECTS
 PLANNERS
 2060 NW BOCA RATON BLVD.
 SUITE 2
 BOCA RATON, FL 33431
 TEL: 561-392-3848
 FAX: 561-392-5402
 WWW.SLATTERYARCHITECTS.COM

ACTIVITY CENTER FOR FLORENCE FULLER CHILD DEVELOPMENT CENTERS WEST CAMPUS
 S.W. 185TH STREET
 BOCA RATON, PALM BEACH COUNTY, FLORIDA

BIDDING NOT FOR CONSTRUCTION
 DATE OF SEAL: 4/2/08
 SLATTERY & ASSOCIATES
 FLORIDA REGISTRATION # AA0003381

ISSUED FOR PERMIT
 ISSUED FOR CONSTRUCTION

KAMM CONSULTING PROJECT # 2016-0024
 PROJECT MANAGER: JOHN CHIRGWIN

KAMM Consulting
 1407 West Newport Center Drive
 Deerfield Beach, Florida 33442
 Phone 954.949.2200 Fax 954.949.2201
 engineering@kammconsulting.com
 Certification of Authorization #8189

10.21.16
 signed

ROOF POWER PLAN

DRAWN	JWC/PG/AE
CHECKED	AK/MP
DATE	10-21-16
SCALE	AS NOTED
JOB NO.	2011-64
SHEET	E3.3

PHASE: C.D. SET 10-21-16