



FLORENCE FULLER WEST CAMPUS LIGHTING FIXTURE SCHEDULE

10/10/2016

Type	Manufacturer	Model#	Lamp	Voltage	Dimming	Accessories	Notes
A1	LITHONIA	2BLT4 48L ADP MVOLT EZ1 LP840	45w INTEGRAL LED	MVOLT	0-10v		
A2	LITHONIA	2BLT2 33L ADP MVOLT EZ1 LP840	39w INTEGRAL LED	MVOLT	0-10v		
A3	LITHONIA	2BLT2 40L ADP MVOLT EZ1 LP840	39w INTEGRAL LED	MVOLT	0-10v		
A4	LITHONIA	2BLT4 60L ADP MVOLT EZ1 LP840	53w INTEGRAL LED	MVOLT	0-10v		
A5	LITHONIA	2BLT4 30L ADP MVOLT EZ1 LP840	30w INTEGRAL LED	MVOLT	0-10v		
B	LITHONIA	LBL4 48L EZ1 LP840	41w INTEGRAL LED	MVOLT	0-10v		
C1	LITHONIA	LDN4 40/25 LO4AR AD MVOLT EZ10	30w INTEGRAL LED	MVOLT	0-10v		
C2	LITHONIA	LDN4 40/05 LO4AR AD MVOLT EZ10	8.5w INTEGRAL LED	MVOLT	0-10v		
D	LITHONIA	LDN6 40/20 LO6AR AD MVOLT EZ10	24w INTEGRAL LED	MVOLT	0-10v		
G	LITHONIA	MRW LED 1 10A700/40K SR3 MVOLT DD**	27w INTEGRAL LED	MVOLT	N/A		** = SELECT FINISH
H	LITHONIA	OLWX1 LED 20W 40K	22w INTEGRAL LED	MVOLT	N/A		
J	BROWNEE	2081-15-WH-C17LED-FL1-40K	17w INTEGRAL LED	120V / 277V	N/A		
L	GOTHAM	ICO 40/07 2AR LD 35D MVOLT UGZ TRW	10w INTEGRAL LED	MVOLT	0-10v or TRIAC / ELEV		
EM	LITHONIA	ELM2 LED	(2) 1.5w LED	120V / 277V	N/A		
X	LITHONIA	LQM S W 3 R 120/277 EL N	92w LED	120V / 277V	N/A		

- NOTES:
- 1) integral low-voltage transformer / ballast / power supply - contractor to verify compatibility with dimming system
 - 2) owner / architect to verify trim finish
 - 3) include remote power supply - contractor to verify compatibility with dimming system
 - 4) include all electrical and mounting accessories, connectors, etc.
 - 5) length in inches per plan
 - 6) dimensions are nominal- contractor to verify exact size prior to fabrication
 - 7) COORDINATE ALL LIGHTING WITH POWER & LIGHTING SYSTEMS, INC.
 - 8) PROVIDE ALL LIGHTING FIXTURES AS SPECIFIED. SUBSTITUTIONS WILL NOT BE ACCEPTED WITHOUT PRIOR APPROVAL FROM THE OWNER AND ARCHITECT.



Power & Lighting
Systems, Inc.
Manufacturer's Representatives
Innovative Specification Systems
392 SW 12 Avenue
Deerfield Beach, FL 33442
phone: (954) 360-7608
fax: (954) 360-7633
website: http://p-ls.com

REVISIONS	BY

Slattery & Associates
ARCHITECTS PLANNERS
2060 NW BOCA RATON BLVD.
SUITE 2
BOCA RATON, FL 33431
TEL: 561-392-3848
FAX: 561-392-5402
WWW.SLATTERYARCHITECTS.COM

ACTIVITY CENTER FOR FLORENCE FULLER CHILD DEVELOPMENT CENTERS WEST CAMPUS S.W. 185TH STREET BOCA RATON, PALM BEACH COUNTY, FLORIDA

BIDDING NOT FOR CONSTRUCTION
DATE OF SEAL: 4/2/08
SLATTERY & ASSOCIATES
FLORIDA REGISTRATION # AA0003381

ISSUED FOR PERMIT
ISSUED FOR CONSTRUCTION
KAMM CONSULTING PROJECT #: 2016-0024
PROJECT MANAGER: JOHN CHIROWIN
KAMM Consulting
1407 West Newport Center Drive
Deerfield Beach, Florida 33442
Phone 954.949.2200 Fax 954.949.2201
engineering@kammconsulting.com
Certification of Authorization #S189
10.21.16
date
signed

ELECTRICAL DETAILS

DRAWN	JWC/PG/AE
CHECKED	AK/MP
DATE	10-21-16
SCALE	AS NOTED
JOB NO.	2011-64
SHEET	E7.1

PHASE: C.D. SET 10-21-16