



WEST PALM BEACH

Purchasing Department

**Addendum 2
ITB 16-17-104
November 23, 2016**

O & M Complex Bldg. #2 Restroom Renovations

Each recipient of this Addendum acknowledges all of the provisions set forth in the Invitation to Bid (ITB) and agrees to be bound by the terms thereof.

This addendum shall modify, clarify, change or add information and become part of the above referenced ITB.

This Addendum shall provide the following information:

- New bid opening location
- Questions and Answers

The following documents are included with this addendum:

- Addendum 2 ITB 16-17-104

New bid opening location

The Procurement Department is now located on the **Third Floor** of City Hall; 401 Clematis Street, West Palm Beach, FL 33401.

The Bid Submittal Deadline remains unchanged: Thursday, December 1, 2016, in the Procurement Department – **Third Floor**, 401 Clematis Street, West Palm Beach, FL 33401 at 3:00 PM. Bids received after the Bid Submittal Deadline will be returned unopened and will not be considered.

Questions and Answers

Question 1: What is the project's anticipated start date?

Answer: The project is anticipated to start in middle to late January, 2017.

Question 2: What is the Engineer's estimate and/or City's budget for the project?

Answer: The City will not provide the Engineer's estimate or the budget for the project.

Question 3: Will the permit fees be reimbursable?

Answer: An allowance for permit fees has been included on the bid form. Contractor shall credit the City the difference if the actual permit fees are less than the allowance. If the actual permit fees exceed the allowance, the City will reimburse the Contractor for the fees in excess of the allowance.

Question 4: What is the deck height above the ceiling?

Answer: The height from the floor to the underside of the metal roof deck is approximately 15'-8"

Question 5: What is the distance to the electrical panel?

Answer: Approximately fifty (50) feet.


Question 6: Will you please verify the door schedule? Specifications call for fiberglass reinforced plastic doors and the door schedule on sheet A-03 states wood and hollow metal.

Answer: The doors and frames shall be painted hollow metal.

All of the other information remains the same.

Proposers must acknowledge receipt of this Addendum 2 in the space provided below. This Addendum forms an integral part of the ITB documents and therefore must be executed. Failure to return this addendum with your proposal submittal may be cause for disqualification.

Issued By: City of West Palm Beach
Procurement Division
November 23, 2016

Signed By: 
Nathaniel P. Rubel
Procurement Supervisor

PROPOSER: _____

Signed By: _____

Print Name: _____

Title: _____

Date: _____

End of Addendum 2