



**1** PROPOSED FLOOR PLAN - LIGHTING  
 E-102 SCALE: 3/16" = 1'-0"

**GENERAL NOTES**

- FIELD VERIFY ALL CIRCUIT INDICATED BY LIGHT FIXTURES, AS INFORMATION IS TAKEN FROM SET OF RECORD DRAWINGS. COMMUNICATE ANY DISCREPANCY OF CIRCUITS TO ENGINEER.

**EMERGENCY LIGHTS NOTE**

HALF SHADED FIXTURES ARE TIED TO THE GENERATOR, THROUGH PANEL EM2, TO PROVIDE EMERGENCY LIGHTING FOR THE SPACE.

NON HALF SHADED FIXTURES, IN KITCHEN, ARE TIED TO THE GENERATOR, THROUGH PANEL K, ALSO TO PROVIDE EMERGENCY LIGHTING FOR THE SPACE.

**KEY NOTES**

- LIGHT FIXTURE TO BE REPLACED WITH NEW 2'X4' FLUORESCENT, GASKETED FIXTURE WITH (2) T8 LAMPS.
- LIGHT FIXTURE TO BE REPLACED WITH NEW 4' FLUORESCENT, COVERED STRIP FIXTURE WITH (2) T8 LAMPS.
- LIGHT FIXTURE TO REMAIN.
- LIGHT FIXTURE TO BE REPLACED WITH NEW 2'X4' FLUORESCENT, FIXTURE WITH (2) T8 LAMPS.
- NEW COMPACT FLUORESCENT LIGHT FIXTURE WITH (1) 32W PLT LAMP.
- EXTEND 2#12, 1#12 GND. IN 1/2" TO EXISTING 2'X4' FIXTURES' CIRCUIT.
- RECONNECT NEW LIGHT FIXTURE TO EMERGENCY CIRCUIT INDICATED.
- RELOCATE EXISTING LIGHT FIXTURE TO NEW LOCATION AS INDICATED, AFTER REPLACING WITH NEW.

**LIGHTING FIXTURE SCHEDULE**

TYPE	DESCRIPTION	MANUFACTURER	CATALOG NUMBER	VOLT	# LAMPS	LAMP TYPE	INPUT WATTS	MOUNTING	REMARKS
A	2' X 4' LENSED FLUORESCENT	WILLIAMS	50G-S24-232-FA12125-DG/MYLAR-EB2-UNV		2	F32T8	58W	RECESS	KITCHEN, DISHWASHING AREA
B	2' X 4' LENSED FLUORESCENT	WILLIAMS	50G-S24-232-FA12125-EB2-UNV		2	F32T8	58W	RECESS	SERVING AREA
C	4' ENCLOSED FLUORESCENT	WILLIAMS	92-4-232-A-EB2-UNV		2	F32T8	58W	SURFACE	
D	COMPACT FLUORESCENT DOWNLIGHT	WILLIAMS	PH75-132T-SG-AC/ICGS-MWT-EB1-UNV		1	32W PLT	37W	RECESS	
X	EXIT SIGN WITH EMERGENCY BATTERY	BEGHELLI	VA4-SA-R		---	LED	4W	UNIVERSAL	

DELTA G CONSULTING  
 ENGINEERS, ARCHITECTS  
 PLUMBING AND MECHANICAL CONTRACTORS  
 707 N.E. 201 Ave., Suite 200, Ft. Lauderdale, FL 33304  
 (954) 561-1112

PROJECT: KITCHEN RENOVATION TO NORTH HOMELESS ASSISTANCE CENTER  
 BROWARD COUNTY  
 1700 BLOUNT ROAD, POMPAHO BEACH, FL

FILE NO.:	15.012
DATE:	07/20/15
DRAWN BY:	SB/JP/DS/RT
CHECKED BY:	GJS

SHEET TITLE: PROPOSED FLOOR PLAN - LIGHTING  
 SHEET NUMBER: E-102

NO.	DESCRIPTION	REVISIONS	DATE	BY
1	BUILDING DEPT. COMMENTS		03/29/16	
2	KITCHEN REDESIGN		08/26/16	
3	CMD COMMENTS		12/02/16	

WE SOLEMNLY SWEAR THAT THESE PLANS AND DESIGN INFORMATION WERE PREPARED BY US OR UNDER OUR CLOSE PERSONAL SUPERVISION AND TO THE BEST OF OUR KNOWLEDGE AND BELIEF THEY COMPLY WITH ALL CITY, STATE AND FEDERAL REQUIREMENTS. WE WILL BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS.